

KLO CAMPUS JOHS COMMITTEE INSPECTION January 14, 2015

- Classrooms A125, A128 and A 138 were occupied and not inspected
- Items are generally classed as Low, Medium and High hazard.
- No items were identified that required immediate attention.
- Generally, poor housekeeping practices were mainly identified for corrective action.

Description	Hazard Level	Action required by March 20	Status/ETA
Minimum 30" clearance was not observed in the following locations: A115; A134; A149; A146.	M	HSEMS to meet with Finance	reconfigured
2 of the Fire extinguishers in the area require wall bracket	M	Work Request W124547-040115	Completed
A 115 and A 143 need a step stool	L	Contact Supervisor of area to recommend.	Submit web req to order
132U jagged desk corner should be repaired or removed	L	Work Request W125268-041615	Completed
A142A + A141 closet area had heavy items stored above shoulder height	M	OHS Officer met with occupants	Closed
A108 in the CS main office had an outlet missing a cover	M	Work Request W124549-040115	Completed
Electrical panels RA and RB are unlocked (A/E)	M	Work Request W124549-040115	Completed
A131 – holes in the wall with exposed wiring	M	Work Request W124549-040115	Completed
Items raised as concern	Hazard Level	Action required by March 20	Status/ETA
T. Nelson requested chair adjustment	M	C Hayman emailed March 9.15	Closed
Muster location points unclear	H	Need to meet with James D.	Referred to KFD
Washroom floors require stripping and cleaning	L	Work Request W125269-041615	Completed

Inspection completed by:		Signature
Jasmine Korcok	Worker Representative	
Arch Doody	Employer Representative	